

Quotation Advert

Opening Date:

04/02/2025

Closing Date:

07/02/2025

Closing Time:

11:00

INSTITUTION DETAILS

Institution Name:

Ladysmith Hospital

Province:

KwaZulu-Natal

Department of entity:

Department of Health

Division or section:

Supply Chain Management

Place where goods/

Ladysmith Regional Hospital

service is required: Date Submitted:

04/02/2025

ITEM CATEGORY AND DETAILS

Quotation number:

LSH1605/24/25

Item Category:

Services

Item Description:

Annual service for air-conditioning slit unit for Ladysmith

Regional Hospital

Quantity:

178

COMPULSORY BRIEFING SESSION / SITE VISIT

Select Type:

Not applicable

Time:

Not applicable

Venue:

Not applicable

QUOTES CAN BE COLLECTED FROM:

Download from KZN Health Website

QUOTATION MUST BE DEPOSITED ON THE TENDER BOX NEXT TO MAIN SECURITY GATE OR EMAIL:Ladysmith.quotation@kznhealth.gov.za

ENQUIRIES REGARDING ADVERT MAY BE DIRECTED TO:

Name:

N.Mvelase

Email:

Ladysmith.quotation@kznhealth.gov.za

Contact number: 036-638 0242

Finance Manager Name:

Mrs N.S Mthembu

Finance Manager Signature: (()



YOU ARE H	HERE	BY IN	IVITED :	TO Q	UOTE F	OR R	EQUIRE	MEN.	TS AT.		***************************************	/SMI					L H	os	PIT.	AL.								
FACSIMILE	. NUM	BER	. 03	6 63	312 32	3			E-	MA	IL AD	DRES	S;	lad	ysn	nith.	que	tati	on(@kz	nhe	alti	n.gc	V,Z	a			
PHYSICAL ,	ADDF	RESS	36	MA	LCOL	vi RC	AD,H	OSF	ITAA	L F	PAR:	K,LA	DY	SMI	TH,	337	0											
QUOTE NU	IMBEI	₹: ˌ	ZNQ	, L	"SH		1 160)5	1	24	· _	. 25	_									VA	LIDI	TY F	ERI	OD:	90	DAYS
DATE ADVE	ERTIS	ED:	04	/02/	2025				CL	.OS	SING [DATE:		07	02/	202	5						CL	4I2C	IG Ti	ME:		11:00
DESCRIPTI	ION:		ANNL	JAL	SERVI	CE F	OR A	IR-C	OND	ITI	ONI	NG S	SLIT	1U	ИТ	FOF	R LA	\D\	/SIV	IITI	l RI	EGI	ON	AL	НО	SPI	ΓAL	
CONTRACT	T PER	lOD	(IF APP	LICA	BLE):	ON	CE																					
DEPOSITED							(STRE	ET AL	DDRES	S):																		
36 MALC							RK,LA	DYS	MITH	1,3	370	(BO)	(Α ⁻	۲M	AIN	GΑ	TE)										
ENQUIRIES	PERS	ON:	N.Mve	elase	-					72			TEL	.EPF	IONI	E NU	MBE	R:	03	6 63	380	242	2					
E-MAIL ADD ENQUIRIES CONTACT F E-MAIL ADD	S REG PERS	ARE	ING <u>TE</u>	CHNI	ICAL INI	ORM.	ATION I				TED	TO: —	TEL	EPH	IONE	E NU	мве	:R:	03	6 6:	380	026	7		-			
Bidders she			re that (sunte	e ara da	llvere	d timec	nielv	to the	cor	rect :	ddras	e If	the	ano	tale	lata	it u	ill n	at be	200	anto	od fo	r co	neld	arati		
The quote b				•			u minec	Justy	io inc		1001	idai c.	J-J-, [1	uic	400	10 13	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	11. 41	(H) 119	J. D.	. 1100	.cp.	,u ,c	,, 00	11510	o, uu	OII.	
QUOTATIO						THE (OFFICIA	L FO	RMS –	· (N:	OT TO) BE	RETY	/PEI)													
THIS QUOT																											NTR	ACT,
					/F4		FOLLOV E TO DO														١							
NAME OF B	BIDDE	R:		iono) (gli inemini (e			ant//elobasillos#2		Andrew Andrew	Vicasibi II	therefore Richmic	Khama Ka	er istiliation	- Bardina iii	id kasilikus	Smoth/John		ndiam doct		blooked			*********					
E-MAIL ADD	DRES	S:																										· · · · · · · · ·
POSTAL AD	ODRE	SS:	,																							~~~~		·
STREET AC	ODRE	SS:																										
TELEPHON	IE NU	MBE	R:										FAC	SIM	ILE	NUM	BER									*****	***************************************	
CELLPHON	IE NU	MBE	R:										SAF	RS P	IN:													
VAT REGIS	STRAT	ION	NUMBE	R (If	VAT ven	dor):						_																
CENTRAL S	SUPP	LIER	DATAB	ASE	REGIST	RATIC	N (CSE) NO	Ī				М	А	Α	А												
UNIQUE RE	EGIST	RAT	ON REI	FERE	NCE:	П	-1	T T	1	T	I	1	T	I	·				<u> </u>	·	· · · · · · · · · · · · · · · · · · ·	<u> </u>	 T	<u>ا</u>	1			
	<u>L</u>				-			-		_							-											



HEALTH HEALTH	SOUTH ATTICA						
			OFFICIAL PRICE PAGE FOR QUOTATIONS UP TO	R4 000 000			
QUOTE NUMBE	R: ZNQ	, LSH	, 1605 , 24 <u>. 25</u>				
DESCRIPTION:	ANNU	JAL SERVI	CE FOR AIR-CONDITIONING SLIT UNIT FO	R LADYSN	MITH REGION	AL HOSPITA	\L
THE BELOW PI PROCUREMEN			L BE ALLOCATED IN COMPLIANCE WITH THE DEPART M PPP):	MENTAL PRI	EFERENCE	POINTS ALL	OCATED
Race; Full points alloca	ited to companies w	no are at least 1009	% Owned by Black Africans			20	
ICN NUMBER	QUANTITY	UNIT OF MEASURE	DESCRIPTION	BRAND & MODEL	COUNTRY OF MANUFACTUR	PRIC	E
	178	UNIT	ANNUAL SERVICE FOR AIR-				Ť
			CONDITIONING SLIT UNIT				
			FOR LADYSMITH REGIONAL HOSPITAL				
			REQUIRED: CIBD GRADING 1ME &				_
			PROOF OF SIMILAR WORK				
			PROOF OF SHVILLAR WORK				
			NB:SEE SPECIFICATION ATTACHED				
							+
		<u>.</u>					
				-			
	-		ND SEE ATTACHED EVALUATION				-
"			NB:SEE ATTACHED EVALUATION CRITERIA PLEASE READ SIGN AND				
			RETURN IT WITH ATTACHMENT				
			REQUIRED			-	
VALUE ADDED	TAX @ 15% (Only if VAT \	/endor)		L		
TOTAL QUOTA	TION PRICE (VALIDITY PE	RIOD 90 Days)				
DOES THIS OFF		WITH THE S	PECIFICATION?				ES / NO
			3.A.N.S. / S.A.B.S. SPECIFICATION?			YE	S / NO
STATE DELIVER			•	nep.			
HUMIT OIL BIDDI			SIGNATURE OF BID (By signing this docu		agree to all terms	and conditions]	
CAPACITY UND	ER WHICH TI	HIS QUOTE I	S SIGNED:		DATE:		



BIDDER'S DISCLOSURE

SBD 4

1 PURPOSE OF THE FORM

Any person (natural or juristic) may make an offer or offers in terms of this invitation to bid. In line with the principles of transparency, accountability, impartiality, and ethics as enshrined in the Constitution of the Republic of South Africa and further expressed in various pieces of legislation, it is required for the bidder to make this declaration in respect of the details required hereunder.

Where a person/s are listed in the Register for Tender Defaulters and I or the List of Restricted Suppliers, that person will automatically be disqualified from the bid process.

2	BIDDER'S	DECL	ARATION
---	----------	------	---------

- 2.1. Is the bidder, or any of its directors / trustees / shareholders / members / partners or any person having a controlling interest in the enterprise, employed by the state?
- 2.1.1. If so, furnish particulars of the names, individual identity numbers, and, if applicable, state employee numbers of sole proprietor/ directors / trustees /

FULL NAME	IDENTITY NUMBER	NAME OF STATE INSTITUTION
1		

2.2.	Do you, or any person connected with the bidder, have a relationship with any person w	ho is employed by the procuring institution ² ?	YES / NO
2.2.1.	If so, furnish particulars:		
2.3.	Does the bidder or any of its directors / trustees / shareholders / members / partners or enterprise have any interest in any other related enterprise whether or not they are bidd		YES / No
2.3.1.	If so, furnish particulars:		West of the second seco
3	DECLARATION		
	I, the undersigned,(name) the following statements that I certify to be true and complete in every respect:	in submitting the accompanying bid, o	do hereby make

- 3.1. I have read and I understand the contents of this disclosure;
- 3.2. I understand that the accompanying bid will be disqualified if this disclosure is found not to be true and complete in every respect;
- 3.3. The bidder has arrived at the accompanying bid independently from, and without consultation, communication, agreement or arrangement with any competitor. However, communication between partners in a joint venture or consortium³ will not be construed as coflusive bidding.
- 3.4. In addition, there have been no consultations, communications, agreements or arrangements with any competitor regarding the quality, quantity, specifications, prices, including methods, factors or formulas used to calculate prices, market allocation, the intention or decision to submit or not to submit the bid, bidding with the intention not to win the bid and conditions or delivery particulars of the products or services to which this bid invitation relates.
- 3.5. The terms of the accompanying bid have not been, and will not be, disclosed by the bidder, directly or indirectly, to any competitor, prior to the date and time of the official bid opening or of the awarding of the contract.
- 3.6. There have been no consultations, communications, agreements or arrangements made by the bidder with any official of the procuring institution in relation to this procurement process prior to and during the bidding process except to provide clarification on the bid submitted where so required by the institution; and the bidder was not involved in the drafting of the specifications or terms of reference for this bid.
- 3.7. I am aware that, in addition and without prejudice to any other remedy provided to combat any restrictive practices related to bids and contracts, bids that are suspicious will be reported to the Competition Commission for investigation and possible imposition of administrative penalties in terms of section 59 of the Competition Act No 89 of 1998 and or may be reported to the National Prosecuting Authority (NPA) for criminal investigation and or may be restricted from conducting business with the public sector for a period not exceeding ten (10) years in terms of the Prevention and Combating of Corrupt Activities Act No 12 of 2004 or any other applicable legislation.

I CERTIFY THAT THE INFORMATION FURNISHED IN PARAGRAPHS 1, 2 and 3 ABOVE IS CORRECT.

I ACCEPT THAT THE STATE MAY REJECT THE BID OR ACT AGAINST ME IN TERMS OF PARAGRAPH 6 OF PFMA SCM INSTRUCTION 03 OF 2021/22 ON PREVENTING AND COMBATING ABUSE IN THE SUPPLY CHAIN MANAGEMENT SYSTEM SHOULD THIS DECLARATION PROVE TO BE FALSE.

	NAME OF BIDDER	SIGNATURE	POSITION	DATE
--	----------------	-----------	----------	------

¹ The power, by one person or a group of persons holding the majority of the equity of an enterprise, alternatively, the person/s having the deciding vote or power to influence or to direct the course and decisions of the enterprise.

^{2 &}quot;Procuring Institution" refers to all institutions under the Accounting Officer of the Department of Health.

³ Joint venture or Consonium means an association of persons for the purpose of combining their expertise, property, capital, efforts, skill and knowledge in an activity for the execution of a contract.

GENERAL CONDITIONS OF CONTRACT

GCC

NOTES

The purpose of this document is to:

- (i) Draw special attention to certain general conditions applicable to government bids, contracts and orders; and
- (ii) To ensure that clients be familiar with regard to the rights and obligations of all parties involved in doing business with government.

in this document words in the singular also mean in the plural and vice versa and words in the masculine also mean in the feminine and neuter.

- The General Conditions of Contract will form part of all bid/quotation documents and may not be amended.
- Special Conditions of Contract (SCC) relevant to a specific bid, should be compiled separately for every bid (if applicable) and will supplement the General Conditions of Contract. Whenever there is a conflict, the provisions in the SCC shall prevail.

1. Definitions

The following terms shall be interpreted as indicated:

- 1.1. "Closing time" means the date and hour specified in the bidding documents for the receipt of bids.
- 1.2. "Contract" means the written agreement entered into between the purchaser and the supplier, as recorded in the contract form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- 1.3. "Contract price" means the price payable to the supplier under the contract for the full and proper performance of his contractual obligations.
- 1.4. "Corrupt practice" means the offering, giving, receiving, or soliciting of any thing of value to influence the action of a public official in the procurement process or in contract execution.
- 1.5. "Countervailing duties" are imposed in cases where an enterprise abroad is subsidized by its government and encouraged to market its products internationally.
- 1.6. "Country of origin" means the place where the goods were mined, grown or produced or from which the services are supplied. Goods are produced when, through manufacturing, processing or substantial and major assembly of components, a commercially recognized new product results that is substantially different in basic characteristics or in purpose or utility from its components.
- 1.7. "Day" means calendar day,
- 1.8. "Delivery" means delivery in compliance of the conditions of the contract or order.
- 1.9. "Delivery ex stock" means immediate delivery directly from stock actually on hand.
- 1.10. "Delivery into consignees store or to his site" means delivered and unloaded in the specified store or depot or on the specified site in compliance with the conditions of the contract or order, the supplier bearing all risks and charges involved until the supplies are so delivered and a valid receipt is obtained.
- 1.11. "Dumping" occurs when a private enterprise abroad market its goods on own initiative in the RSA at lower prices than that of the country of origin and which have the potential to harm the local industries in the RSA
- 1.12. "Force majeure" means an event beyond the control of the supplier and not involving the supplier's fault or negligence and not foreseeable. Such events may include, but is not restricted to, acts of the purchaser in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions and freight embargoes.
- 1.13. "Fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of any bidder, and includes collusive practice among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the bidder of the benefits of free and open competition.
- 1.14. "GCC" means the General Conditions of Contract.
- 1.15. "Goods" means all of the equipment, machinery, and/or other materials that the supplier is required to supply to the purchaser under the contract.
- 1.16. "Imported content" means that portion of the bidding price represented by the cost of components, parts or materials which have been or are still to be imported (whether by the supplier or his subcontractors) and which costs are inclusive of the costs abroad, plus freight and other direct importation costs such as landing costs, dock dues, import duty, sales duty or other similar tax or duty at the South African place of entry as well as transportation and handling charges to the factory in the Republic where the supplies covered by the bid will be manufactured.
- 1.17. "Local content" means that portion of the bidding price which is not included in the imported content provided that local manufacture does take place.
- 1.18. "Manufacture" means the production of products in a factory using labour, materials, components and machinery and includes other related value-adding
- 1,19. "Order" means an official written order issued for the supply of goods or works or the rendering of a service.
- 1.20. "Project site," where applicable, means the place indicated in bidding documents.
- 1.21. "Purchaser" means the organization purchasing the goods.
- 1.22. "Republic" means the Republic of South Africa.
- 1.23. "SCC" means the Special Conditions of Contract.
- 1.24. "Services" means those functional services ancillary to the supply of the goods, such as transportation and any other incidental services, such as installation, commissioning, provision of technical assistance, training, catering, gardening, security, maintenance and other such obligations of the supplier covered under the contract.
- 1.25. "Written" or "In writing" means handwritten in ink or any form of electronic or mechanical writing.

2. Application

- 2.1. These general conditions are applicable to all bids, contracts and orders including bids for functional and professional services, sales, hiring, letting and the granting or acquiring of rights, but excluding immovable property, unless otherwise indicated in the bidding documents.
- 2.2. Where applicable, special conditions of contract are also laid down to cover specific supplies, services or works.
- 2.3. Where such special conditions of contract are in conflict with these general conditions, the special conditions shall apply.

3, General

- 3.1. Unless otherwise indicated in the bidding documents, the purchaser shall not be liable for any expense incurred in the preparation and submission of a bid. Where applicable a non-refundable fee for documents may be charged.
- 3.2. With certain exceptions, invitations to bid are only published in the Government Tender Bulletin. The Government Tender Bulletin may be obtained directly from the Government Printer, Private Bag X85, Pretoria 0001, or accessed electronically from www.lreasury.gov.za



4. Standards

- 4.1. The goods supplied shall conform to the standards mentioned in the bidding documents and specifications.
- Use of contract documents and information; inspection.
- 5.1. The supplier shall not, without the purchaser's prior written consent, disclose the contract, or any provision thereof, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the purchaser in connection therewith, to any person other than a person employed by the supplier in the performance of the contract. Disclosure to any such employed person shall be made in confidence and shall extend only so far as may be necessary for purposes of such performance.
- 5.2. The supplier shall not, without the purchaser's prior written consent, make use of any document or information mentioned in GCC clause 5.1 except for purposes of performing the contract.
- 5.3. Any document, other than the contract itself mentioned in GCC clause 5.1 shall remain the property of the purchaser and shall be returned (all copies) to the purchaser on completion of the supplier's performance under the contract if so required by the purchaser.
- 5.4. The supplier shall permit the purchaser to inspect the supplier's records relating to the performance of the supplier and to have them audited by auditors appointed by the purchaser, if so required by the purchaser.

Patent rights

6.1. The supplier shall indemnify the purchaser against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the goods or any part thereof by the purchaser.

Performance security

- 7.1. Within thirty (30) days of receipt of the notification of contract award, the successful bidder shall furnish to the purchaser the performance security of the amount specified in SCC.
- 7.2. The proceeds of the performance security shall be payable to the purchaser as compensation for any loss resulting from the supplier's failure to complete his obligations under the contract.
- 7.3. The performance security shall be denominated in the currency of the contract, or in a freely convertible currency acceptable to the purchaser and shall be in one of the following forms:
 - (a) a bank guarantee or an irrevocable letter of credit issued by a reputable bank located in the purchaser's country or abroad, acceptable to the purchaser, in the form provided in the bidding documents or another form acceptable to the purchaser; or
 - (b) a cashier's or certified cheque
- 7.4. The performance security will be discharged by the purchaser and returned to the supplier not later than thirty (30) days following the date of completion of the supplier's performance obligations under the contract, including any warranty obligations, unless otherwise specified in SCC.

8. Inspections, tests and analyses

- 8.1. All pre-bidding testing will be for the account of the bidder.
- 8.2. If it is a bid condition that supplies to be produced or services to be rendered should at any stage during production or execution or on completion be subject to inspection, the premises of the bidder or contractor shall be open, at all reasonable hours, for inspection by a representative of the Department or an organization acting on behalf of the Department.
- 8.3. If there are no inspection requirements indicated in the bidding documents and no mention is made in the contract, but during the contract period it is decided that inspections shall be carried out, the purchaser shall itself make the necessary arrangements, including payment arrangements with the testing authority concerned.
- 8.4. If the inspections, tests and analyses referred to in clauses 8.2 and 8.3 show the supplies to be in accordance with the contract requirements, the cost of the inspections, tests and analyses shall be defrayed by the purchaser.
- 8.5. Where the supplies or services referred to in clauses 8,2 and 8,3 do not comply with the contract requirements, irrespective of whether such supplies or services are accepted or not, the cost in connection with these inspections, tests or analyses shall be defrayed by the supplier.
- 8.6. Supplies and services which are referred to in clauses 8.2 and 8.3 and which do not comply with the contract requirements may be rejected.
- 8.7. Any contract supplies may on or after delivery be inspected, tested or analyzed and may be rejected if found not to comply with the requirements of the contract. Such rejected supplies shall be held at the cost and risk of the supplier who shall, when called upon, remove them immediately at his own cost and forthwith substitute them with supplies which do comply with the requirements of the contract. Failing such removal the rejected supplies shall be returned at the suppliers cost and risk. Should the supplier fail to provide the substitute supplies forthwith, the purchaser may, without giving the supplier further opportunity to substitute the rejected supplies, purchase such supplies as may be necessary at the expense of the supplier.
- 8.8. The provisions of clauses 8.4 to 8.7 shall not prejudice the right of the purchaser to cancel the contract on account of a breach of the conditions thereof, or to act in terms of Clause 23 of GCC.

9. Packing

- 9.1. The supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the contract. The packing shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit, and open storage. Packing, case size and weights shall take into consideration, where appropriate, the remoteness of the goods' final destination and the absence of heavy handling facilities at all points in transit.
- 9.2. The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the contract, including additional requirements, if any, specified in SCC, and in any subsequent instructions ordered by the purchaser.

10. Delivery and documents

- 10.1. Delivery of the goods shall be made by the supplier in accordance with the terms specified in the contract. The details of shipping and/or other documents to be furnished by the supplier are specified in SCC.
- 10.2. Documents to be submitted by the supplier are specified in SCC.

11. Insurance

11.1. The goods supplied under the contract shall be fully insured in a freely convertible currency against loss or damage incidental to manufacture or acquisition, transportation, storage and delivery in the manner specified in the SCC.



12. Transportation

12.1. Should a price other than an all-inclusive delivered price be required, this shall be specified in the SCC.

13. Incidental services

- 13.1. The supplier may be required to provide any or all of the following services, including additional services, if any, specified in SCC:
 - (a) performance or supervision of on-site assembly and/or commissioning of the supplied goods;
 - (b) furnishing of tools required for assembly and/or maintenance of the supplied goods;
 - (c) furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied goods;
 - (d) performance or supervision or maintenance and/or repair of the supplied goods, for a period of time agreed by the parties, provided that this service shall not relieve the supplier of any warranty obligations under this contract; and
 - (e) training of the purchaser's personnel, at the supplier's plant and/or on-site, in assembly, start-up, operation, maintenance, and/or repair of the
- 13.2. Prices charged by the supplier for incidental services, if not included in the contract price for the goods, shall be agreed upon in advance by the parties and shall not exceed the prevailing rates charged to other parties by the supplier for similar services.

14. Spare parts

As specified in SCC, the supplier may be required to provide any or all of the following materials, notifications, and information pertaining to spare parts 14.1. manufactured or distributed by the supplier:

- (a) such spare parts as the purchaser may elect to purchase from the supplier, provided that this election shall not relieve the supplier of any warranty obligations under the contract: and
- (b) in the event of termination of production of the spare parts:
 - (i) Advance notification to the purchaser of the pending termination, in sufficient time to permit the purchaser to procure needed requirements; and
 - (ii) following such termination, furnishing at no cost to the purchaser, the blueprints, drawings, and specifications of the spare parts, if requested.

15. Warranty

- 15.1. The supplier warrants that the goods supplied under the contract are new, unused, of the most recent or current models, and that they incorporate all recent improvements in design and materials unless provided otherwise in the contract. The supplier further warrants that all goods supplied under this contract shall have no defect, arising from design, materials, or workmanship (except when the design and/or material is required by the purchaser's specifications) or from any act or omission of the supplier, that may develop under normal use of the supplied goods in the conditions prevailing in the country of final destination.
- 15.2. This warranty shall remain valid for twelve (12) months after the goods, or any portion thereof as the case may be, have been delivered to and accepted at the final destination indicated in the contract, or for eighteen (18) months after the date of shipment from the port or place of loading in the source country, whichever period concludes earlier, unless specified otherwise in SCC.
- 15.3. The purchaser shall promptly notify the supplier in writing of any claims arising under this warranty.
- 15.4. Upon receipt of such notice, the supplier shall, within the period specified in SCC and with all reasonable speed, repair or replace the defective goods or parts thereof, without costs to the purchaser.
- 15.5. If the supplier, having been notified, fails to remedy the defect(s) within the period specified in SCC, the purchaser may proceed to take such remedial action as may be necessary, at the supplier's risk and expense and without prejudice to any other rights which the purchaser may have against the supplier under the contract.

16, Payment

- 16.1. The method and conditions of payment to be made to the supplier under this contract shall be specified in SCC.
- 16.2. The supplier shall furnish the purchaser with an invoice accompanied by a copy of the delivery note and upon fulfillment of other obligations stipulated in the contract.
- 16.3. Payments shall be made promptly by the purchaser, but in no case later than thirty (30) days after submission of an invoice or claim by the supplier.
- 16.4. Payment will be made in Rand unless otherwise stipulated in SCC.

17. Prices

17.1. Prices charged by the supplier for goods delivered and services performed under the contract shall not vary from the prices quoted by the supplier in his bid, with the exception of any price adjustments authorized in SCC or in the purchaser's request for bid validity extension, as the case may be.

Contract amendments

18.1. No variation in or modification of the terms of the contract shall be made except by written amendment signed by the parties concerned.

19. Assignment

19.1. The supplier shall not assign, in whole or in part, its obligations to perform under the contract, except with the purchaser's prior written consent.

20. Subcontracts

20.1. The supplier shall notify the purchaser in writing of all subcontracts awarded under this contracts if not already specified in the bid. Such notification, in the original bid or later, shall not relieve the supplier from any liability or obligation under the contract.

21. Delays in the supplier's performance

- 21.1. Delivery of the goods and performance of services shall be made by the supplier in accordance with the time schedule prescribed by the purchaser in the contract.
- 21.2. If at any time during performance of the contract, the supplier or its subcontractor(s) should encounter conditions impeding timely delivery of the goods and performance of services, the supplier shall promptly notify the purchaser in writing of the fact of the delay, its likely duration and its cause(s). As soon as practicable after receipt of the supplier's notice, the purchaser shall evaluate the situation and may at his discretion extend the supplier's time for performance, with or without the imposition of penalties, in which case the extension shall be ratified by the parties by amendment of contract.
- 21.3. No provision in a contract shall be deemed to prohibit the obtaining of supplies or services from a national department, provincial department, or a local authority.
- 21.4. The right is reserved to procure outside of the contract small quantities or to have minor essential services executed if an emergency arises, the supplier's point of supply is not situated at or near the place where the supplies are required, or the supplier's services are not readily available.



- 21.5. Except as provided under GCC Clause 25, a delay by the supplier in the performance of its delivery obligations shall render the supplier liable to the imposition of penalties, pursuant to GCC Clause 22, unless an extension of time is agreed upon pursuant to GCC Clause 21.2 without the application of penalties.
- 21.6. Upon any delay beyond the delivery period in the case of a supplies contract, the purchaser shall, without canceling the contract, be entitled to purchase supplies of a similar quality and up to the same quantity in substitution of the goods not supplied in conformity with the contract and to return any goods delivered later at the supplier's expense and risk, or to cancel the contract and buy such goods as may be required to complete the contract and without prejudice to his other rights, be entitled to claim damages from the supplier.

22. Penalties

22.1. Subject to GCC Clause 25, if the supplier fails to deliver any or all of the goods or to perform the services within the period(s) specified in the contract, the purchaser shall, without prejudice to its other remedies under the contract, deduct from the contract price, as a penalty, a sum calculated on the delivered price of the delayed goods or unperformed services using the current prime interest rate calculated for each day of the delay until actual delivery or performance. The purchaser may also consider termination of the contract pursuant to GCC Clause 23.

23. Termination for default

- 23.1. The purchaser, without prejudice to any other remedy for breach of contract, by written notice of default sent to the supplier, may terminate this contract in whole or in part:
 - (a) if the supplier fails to deliver any or all of the goods within the period(s) specified in the contract, or within any extension thereof granted by the purchaser pursuant to GCC Clause 21.2;
 - (b) if the Supplier fails to perform any other obligation(s) under the contract; or
 - (c) If the supplier, in the judgment of the purchaser, has engaged in corrupt or fraudulent practices in competing for or in executing the contract.
- 23.2. In the event the purchaser terminates the contract in whole or in part, the purchaser may procure, upon such terms and in such manner as it deems appropriate, goods, works or services similar to those undelivered, and the supplier shall be liable to the purchaser for any excess costs for such similar goods, works or services. However, the supplier shall continue performance of the contract to the extent not terminated.
- 23.3. Where the purchaser terminates the contract in whole or in part, the purchaser may decide to impose a restriction penalty on the supplier by prohibiting such supplier from doing business with the public sector for a period not exceeding 10 years.
- 23.4. If a purchaser intends imposing a restriction on a supplier or any person associated with the supplier, the supplier will be allowed a time period of not more than fourteen (14) days to provide reasons why the envisaged restriction should not be imposed. Should the supplier fail to respond within the stipulated fourteen (14) days the purchaser may regard the intended penalty as not objected against and may impose it on the supplier.
- 23.5. Any restriction imposed on any person by the Accounting Officer / Authority will, at the discretion of the Accounting Officer / Authority, also be applicable to any other enterprise or any partner, manager, director or other person who wholly or partly exercises or exercised or may exercise control over the enterprise of the first-mentioned person, and with which enterprise or person the first-mentioned person, is or was in the opinion of the Accounting Officer / Authority actively associated.
- 23.6. If a restriction is imposed, the purchaser must, within five (5) working days of such imposition, furnish the National Treasury, with the following information:
 - (i) the name and address of the supplier and I or person restricted by the purchaser;
 - (ii) the date of commencement of the restriction
 - (iii) the period of restriction; and
 - (iv) the reasons for the restriction.
- These details will be loaded in the National Treasury's central database of suppliers or persons prohibited from doing business with the public sector,

 23.7. If a court of law convicts a person of an offence as contemplated in sections 12 or 13 of the Prevention and Combating of Corrupt Activities Act, No. 12 of
 2004, the court may also rule that such person's name be endorsed on the Register for Tender Defaulters. When a person's name has been endorsed
 on the Register, the person will be prohibited from doing business with the public sector for a period not less than five years and not more than 10 years.
 The National Treasury is empowered to determine the period of restriction and each case will be dealt with on its own merits. According to section 32 of
 the Act the Register must be open to the public. The Register can be perused on the National Treasury website.

24. Anti-dumping and countervalling duties and rights

24.1. When, after the date of bid, provisional payments are required, or antidumping or countervailing duties are imposed, or the amount of a provisional payment or anti-dumping or countervailing right is increased in respect of any dumped or subsidized import, the State is not liable for any amount so required or imposed, or for the amount of any such increase. When, after the said date, such a provisional payment is no longer required or any such anti-dumping or countervailing right is abolished, or where the amount of such provisional payment or any such right is reduced, any such favourable difference shall on demand be paid forthwith by the contractor to the State or the State may deduct such amounts from moneys (if any) which may otherwise be due to the contractor in regard to supplies or services which he delivered or rendered, or is to deliver or render in terms of the contract or any other amount whichmay be due to him.

25. Force Majeure

- 25.1. Notwithstanding the provisions of GCC Clauses 22 and 23, the supplier shall not be liable for forfeilure of its performance security, damages, or termination for default if and to the extent that his delay in performance or other failure to perform his obligations under the contract is the result of an event of force majeure.
- 25.2. If a force majeure situation arises, the supplier shall promptly notify the purchaser in writing of such condition and the cause thereof. Unless otherwise directed by the purchaser in writing, the supplier shall continue to perform its obligations under the contract as far as is reasonably practical, and shall seek all reasonable alternative means for performance not prevented by the force majeure event.

26. Termination for insolvency

26.1. The purchaser may at any time terminate the contract by giving written notice to the supplier if the supplier becomes bankrupt or otherwise insolvent. In this event, termination will be without compensation to the supplier, provided that such termination will not prejudice or affect any right of action or remedy which has accrued or will accrue thereafter to the purchaser.

27. Settlement of Disputes

27.1. If any dispute or difference of any kind whatsoever arises between the purchaser and the supplier in connection with or arising out of the contract, the parties shall make every effort to resolve amicably such dispute or difference by mutual consultation.





- 27.2. If, after thirty (30) days, the parties have failed to resolve their dispute or difference by such mutual consultation, then either the purchaser or the supplier may give notice to the other party of his intention to commence with mediation. No mediation in respect of this matter may be commenced unless such notice is given to the other party.
- 27.3. Should it not be possible to settle a dispute by means of mediation, it may be settled in a South African court of law.
- 27.4. Mediation proceedings shall be conducted in accordance with the rules of procedure specified in the SCC.
- 27.5. Notwithstanding any reference to mediation and/or court proceedings herein,
 - (a) the parties shall continue to perform their respective obligations under the contract unless they otherwise agree; and
 - (b) the purchaser shall pay the supplier any monies due the supplier.

28. Limitation of liability

- 28.1. Except in cases of criminal negligence or willful misconduct, and in the case of Infringement pursuant to Clause 6;
 - (a) the supplier shall not be liable to the purchaser, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits or interest costs, provided that this exclusion shall not apply to any obligation of the supplier to pay penalties and/or damages to the purchaser; and
 - (b) the aggregate liability of the supplier to the purchaser, whether under the contract, in tort or otherwise, shall not exceed the total contract price, provided that this limitation shall not apply to the cost of repairing or replacing defective equipment.

29. Governing language

29.1. The contract shall be written in English. All correspondence and other documents pertaining to the contract that is exchanged by the parties shall also be written in English.

30. Applicable law

30.1. The contract shall be interpreted in accordance with South African laws, unless otherwise specified in SCC.

31. Notices

- 31.1. Every written acceptance of a bid shall be posted to the supplier concerned by registered or certified mail and any other notice to him shall be posted by ordinary mail to the address furnished in his bid or to the address notified later by him in writing and such posting shall be deemed to be proper service of such notice
- 31.2. The time mentioned in the contract documents for performing any act after such aforesald notice has been given, shall be reckoned from the date of posting of such notice.

32, Taxes and duties

- 32.1. A foreign supplier shall be entirely responsible for all taxes, stamp duties, license fees, and other such levies imposed outside the purchaser's country.
- 32.2. A local supplier shall be entirely responsible for all taxes, duties, license fees, etc., incurred until delivery of the contracted goods to the purchaser.
- 32.3. No contract shall be concluded with any bidder whose tax matters are not in order. Prior to the award of a bid the Department must be in possession of a tax clearance certificate, submitted by the bidder, This certificate must be an original issued by the South African Revenue Services.

33. National Industrial Participation (NIP) Programme

33,1. The NIP Programme administered by the Department of Trade and Industry shall be applicable to all contracts that are subject to the NIP obligation.

Prohibition of Restrictive practices

- 34.1. In terms of section 4 (1) (b) (iii) of the Competition Act No. 89 of 1998, as amended, an agreement between, or concerted practice by, firms, or a decision by an association of firms, is prohibited if it is between parties in a horizontal relationship and if a bidder (s) is / are or a contractor(s) was / were involved in collusive bidding (or bid rigging).
- 34.2. If a bidder(s) or contractor(s), based on reasonable grounds or evidence obtained by the purchaser, has / have engaged in the restrictive practice referred to above, the purchaser may refer the matter to the Competition Commission for investigation and possible imposition of administrative penalties as contemplated in the Competition Act No. 89 of 1998.
- 34.3. If a bidder(s) or contractor(s), has / have been found guilty by the Competition Commission of the restrictive practice referred to above, the purchaser may, in addition and without prejudice to any other remedy provided for, invalidate the bid(s) for such item(s) offered, and / or terminate the contract in whole or part, and / or restrict the bidder(s) or contractor(s) from conducting business with the public sector for a period not exceeding ten (10) years and / or claim damages from the bidder(s) or contractor(s) concerned.



SPECIAL CONDITIONS OF CONTRACT

SCC

AMENDMENT OF CONTRACT

1.1. Any amendment to or renunciation of the provisions of the contract shall at all times be done in writing and shall be signed by both parties.

2. CHANGE OF ADDRESS

2.1. Bidders must advise the Department of Health (institution where the offer was submitted) should their address (domicilium citandi et executandi) details change from the time of bidding to the expiry of the contract.

3. GENERAL CONDITIONS ATTACHED TO THIS QUOTATION

- 3.1. The Department is under no obligation to accept the lowest or any quote.
- 3.2. The Department reserves the right to communicate in writing with vendors in cases where information is incomplete or where there are obscurities regarding technical aspects of the offer, to obtain confirmation of prices or preference claims in cases where it is evident that a typing, written, transfer or unit error has been made, to investigate the vendor's standing and ability to complete the supply/service satisfactorily.
- 3.3. ALL DECISIONS TAKEN BY THE DEPARTMENT ARE FINAL, INCLUDING THE AWARD OR CANCELLATION OF THIS QUOTATION.
- 3.4. The price quoted must include VAT (if VAT vendor),
- 3.5. Should a bidder become a VAT vendor after award or during the implementation of a contract, they may not request the VAT percentage from the Department as the service provider made an offer during the period they were not registered as a VAT vendor. The Department is only liable for any VAT from registered VAT vendors as originally stated on the quotation document.
- 3.6. The bidder must ensure the correctness & validity of the quotation:
 - (i) that the price(s), rate(s) & preference quoted cover all for the work/item (s) & accept that any mistakes regarding the price (s) & calculations will be at the bidder's risk;
 - (ii) It is the responsibility of the bidder to confirm receipt of their quotation and to keep proof thereof.
- 3.7. The bidder must accept full responsibility for the proper execution & fulfilment of all obligations conditions devolving on under this agreement, as the Principal (s) liable for the due fulfilment of this contract.
- 3.8. This quotation will be evaluated based on the preferential procurement points system, specification, correctness of information and/or functionality criteria, All required documentation must be completed in full and submitted.
- 3.9. Offers must comply strictly with the specification.
- 3.10. Only offers that meet or are greater than the specification will be considered.
- 3.11. Late offers will not be considered.
- 3.12. Expired product/s will not be accepted. All products supplied must be valid for a minimum period of six months.
- 3.13. Used/ second-hand products will not be accepted.
- 3.14. A bidder not registered on the Central Suppliers Database or whose verification has failed will not be considered.
- 3.15. All delivery costs must be included in the quoted price for delivery at the prescribed destination.
- 3.16. Only firm prices will be accepted. Such prices must remain firm for the contract period. Non-firm prices (including rates of exchange variations) will not be considered.
- 3.17. In cases where different delivery points influence the pricing, a separate pricing schedule must be submitted for each delivery point.
- 3.18. In the event of a bidder having multiple quotes, only the cheapest according to specification will be considered.
- 3.19. Verification will be conducted to identify if bidders have multiple companies and are cover-quoting for this bid.
- 3.20. In such instances, the Department reserves the right to immediately disqualify such bidders as cover-quoting is an offence that represents both corruption and acquisition fraud.
- 3.21. Should there be a variation in price and such variation is above the order amount, the Department will reserve the right to place a new order.

4. NEGOTIATIONS

4.1. The Department reserves the right to negotiate with the shortlisted bidder/s prior or post award. The terms and conditions for negotiations will be communicated to the shortlisted bidder/s prior to invitation to negotiations. This will be done to ensure value for money and where the bidder/s price is deemed to be exorbitant, uneconomical or not market related.

5, SPECIAL INSTRUCTIONS AND NOTICES TO BIDDERS REGARDING THE COMPLETION OF THIS QUOTATION.

- 5.1. Unless inconsistent with or expressly indicated otherwise by the context, the singular shall include the plural and vice versa and with words importing the masculine gender shall include the feminine and the neuter,
- 5.2. Under no circumstances whatsoever may the quotation/bid forms be retyped or redrafted. Photocopies of the original bid documentation may be used, but an original signature must appear on such photocopies.
- 5,3. The bidder is advised to check the number of pages and to satisfy himself that none are missing or duplicated.
- 5.4. Quotations submitted must be complete in all respects. However, where it is identified that information in a bidder's response, which does not affect the preference points or price, is incomplete in any respect, the said supplier meets all specification requirements and scores the highest points in terms of preference points and price, the Department reserves the right to request the bidder to complete/ submit such information.
- 5.5. Any alteration made by the bidder must be initialled; failure to do so may render the response invalid.
- 5,6. Use of correcting fluid is prohibited and may render the response invalid.
- 5.7. Quotations will be opened in public as soon as practicable after the closing time of quotation.
- 5.8. Where practical, prices are made public at the time of opening quotations.
- 5.9. If it is desired to make more than one offer against any individual item, such offers should be given on a photocopy of the page in question. Clear indication thereof must be stated on the schedules attached.
- 5,10. The Department is under no obligation to pay suppliers in part for work done if the supplier can no longer for fulfill their obligation.

6. SPECIAL INSTRUCTIONS REGARDING HAND DELIVERED QUOTATIONS

6.1. Quotation shall be lodged at the address indicated not later than the closing time specified for their receipt, and in accordance with the directives in the quotation documents.



- 6.2. Each quotation shall be addressed in accordance with the directives in the quotation documents and shall be lodged in a separate sealed envelope, with the name and address of the bidder, the quotation number and closing date indicated on the envelope. The envelope shall not contain documents relating to any quotation other than that shown on the envelope. If this provision is not complied with, such quotations/bids may be rejected as being invalid.
- 6.3. All quotations received in sealed envelopes with the relevant quotation numbers on the envelopes are kept unopened in safe custody until the closing time of the quotation/bids. Where, however, a quotation is received open, it shall be sealed. If it is received without a quotation/bid number on the envelope, it shall be opened, the quotation number ascertained, the envelope sealed and the quotation number written on the envelope.
- 6.4. A specific box is provided for the receipt of quotations, and no quotation found in any other box or elsewhere subsequent to the closing date and time of quotation will be considered.
- 6,5, Quotation documents must not be included in packages containing samples. Such quotations may be rejected as being invalid.

SAMPLES

- 7.1. In the case of the quote document stipulating that samples are required, the supplier will be informed in due course when samples should be provided to the institution. (This decreases the time of safety and storage risk that may be incurred by the respective institution). The bidders sample will be retained if such bidder wins the contract.
 - (i) If a company/s who has not won the quote requires their samples, they must advise the institution in writing of such.
 - (ii) If samples are not collected within three months of close of quote the institution reserves the right to dispose of them at their discretion.
- 7.2. Samples must be made available when requested in writing or If stipulated on the document.
 - If a Bidder fails to provide a sample of their product on offer for scrutliny against the set specification when requested, their offer will be rejected. All (i) testing will be for the account of the bidder.

8. COMPULSORY SITE INSPECTION / BRIEFING SESSION

8.1. Bidders who fail to attend the compulsory meeting will be disqualified from the evaluation process,

(li) Date:	 1	Time;	:	Place:
Institution Stamp:			Institution Sit	te Inspection / briefing session Official:
			Full Name:	
			Signature:	
			Date:	

- 9. STATEMENT OF SUPPLIES AND SERVICES
- 9.1. The contractor shall, when requested to do so, furnish particulars of supplies delivered or services executed. If he/she fails to do so, the Department may, without prejudice to any other rights which it may have, institute inquiries at the expense of the contractor to obtain the required particulars.
- 10. SUBMISSION AND COMPLETION OF SBD 6.1
- 10.1. Should a bidder wish to qualify for preference points they must complete a SBD 6.1 document. Failure by a bidder to provide all relevant information required, will result in such a bidder not being considered for preference point's allocation. The preferences applicable on the closing date will be utilized. Any changes after the closing date will not be considered for that particular quote.

11. TAX COMPLIANCE REQUIREMENTS

- 11.1. In the event that the tax compliance status has falled on CSD, it is the suppliers' responsibility to provide a SARS pin in order for the institution to validate the tax compliance status of the supplier.
- 11.2. In the event that the institution cannot validate the suppliers' tax clearance on SARS as well as the Central Suppliers Database, the quote will not be considered and passed over as non-compliant according to National Treasury Instruction Note 4 (a) 2016/17.

12. TAX INVOICE

- 12.1. A tax invoice shall be in the currency of the Republic of South Africa and shall contain the following particulars:
 - (i) the name, address and registration number of the supplier;
 - (ii) the name and address of the recipient;
 - (iii) an individual serialized number and the date upon which the tax invoice
 - (iv) a description and quantity or volume of the goods or services supplied;
 - (v) the official department order number issued to the supplier;
 - (vi) the value of the supply, the amount of tax charged;
 - (vii) the words tax invoice in a prominent place.

13. PATENT RIGHTS

13.1. The supplier shall indemnify the KZN Department of Health (hereafter known as the purchaser) against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the goods or any part thereof by the purchaser.

14. PENALTIES

14.1. If at any time during the contract period, the service provider is unable to perform in a timely manner, the service provider must notify the institution in writing/email of the cause of and the duration of the delay. Upon receipt of the notification, the institution should evaluate the circumstances and, if deemed necessary, the institution may extend the service provider's time for performance.

STANDARD QUOTATION DOCUMENT UP TO R1 000 000



- 14.2. In the event of delayed performance that extends beyond the delivery period, the institution is entitled to purchase commodities of a similar quantity and quality as a substitution for the outstanding commodities, without terminating the contract, as well as return commodities delivered at a later stage at the service provider's expense.
- Alternatively, the institution may elect to terminate the contract and procure the necessary commodities in order to complete the contract. In the event that the contract is terminated the institution may claim damages from the service provider in the form of a penalty. The service provider's performance should be captured on the service provider database in order to determine whether or not the service provider should be awarded any contracts in the future.
- 14.4. If the supplier fails to deliver any or all of the goods or to perform the services within the period(s) specified in the contract, the purchaser shall, without prejudice to its other remedies under the contract, deduct from the contract price, as a penalty, a sum calculated on the delivered price of the delayed goods or unperformed services using the current prime interest rate calculated for each day of the delay until actual delivery or performance.

15. TERMINATION FOR DEFAULT

- 15.1. The purchaser, without prejudice to any other remedy for breach of contract, by written notice of default sent to the supplier, may terminate this contract in whole or in part:
 - (i) if the supplier fails to deliver any or all of the goods within the period(s) specified in the contract,
 - (ii) if the supplier fails to perform any other obligation(s) under the contract; or
 - (iii) if the supplier, in the judgment of the purchaser, has engaged in corrupt or fraudulent practices in competing for or in executing the contract.
- 15.2. In the event the purchaser terminates the contract in whole or in part, the purchaser may procure, upon such terms and in such manner as it deems appropriate, goods, works or services similar to those undelivered, and the supplier shall be liable to the purchaser for any excess costs for such similar goods, works or services.
- 15.3. Where the purchaser terminates the contract in whole or in part, the purchaser may decide to impose a restriction penalty on the supplier by prohibiting such supplier from doing business with the public sector for a period not exceeding 10 years.
- 16. THE DEPARTMENT RESERVES THE RIGHT TO PASS OVER ANY QUOTATION WHICH FAILS TO COMPLY WITH THE ABOVE.



SBD 6.1.

PREFERENCE POINTS CLAIM FORM IN TERMS OF THE PREFERENTIAL PROCUREMENT REGULATIONS 2022

This preference form must form part of all tenders invited. It contains general information and serves as a claim form for preference points for specific goals.

NB: BEFORE COMPLETING THIS FORM, TENDERERS MUST STUDY THE GENERAL CONDITIONS, DEFINITIONS AND DIRECTIVES APPLICABLE IN RESPECT OF THE TENDER AND PREFERENTIAL PROCUREMENT REGULATIONS, 2022

1. GENERAL CONDITIONS

- 1.1. The following preference point systems are applicable to invitations to tender:
 - the 80/20 system for requirements with a Rand value of up to R50 000 000 (all applicable taxes included); and
 - the 90/10 system for requirements with a Rand value above R50 000 000 (all applicable taxes included).
- 1.2. The applicable preference point system for this tender is the 80/20 preference point system.
- 1.3. Points for this tender (even in the case of a tender for income-generating contracts) shall be awarded for:
 - (a) Price: and
 - (b) Specific Goals.
- 1.4. The maximum points for this tender are allocated as follows:

	POINTS
PRICE	80
SPECIFIC GOALS	20
Total points for Price and Specific Goals	100

- 1.5. Failure on the part of a tenderer to submit proof or documentation required in terms of this tender to claim points for specific goals with the tender, will be interpreted to mean that preference points for specific goals are not claimed.
- 1.6. The organ of state reserves the right to require of a tenderer, either before a tender is adjudicated or at any time subsequently, to substantiate any claim in regard to preferences, in any manner required by the organ of state.

2. DEFINITIONS

- (a) "tender" means a written offer in the form determined by an organ of state in response to an invitation to provide goods or services through price quotations, competitive tendering process or any other method envisaged in legislation;
- (b) "price" means an amount of money tendered for goods or services, and includes all applicable taxes less all unconditional discounts;
- (c) "rand value" means the total estimated value of a contract in Rand, calculated at the time of bid invitation, and includes all applicable taxes;
- (d) "tender for income-generating contracts" means a written offer in the form determined by an organ of state in response to an invitation for the origination of income-generating contracts through any method envisaged in legislation that will result in a legal agreement between the organ of state and a third party that produces revenue for the organ of state, and includes, but is not limited to, leasing and disposal of assets and concession contracts, excluding direct sales and disposal of assets through public auctions; and
- (e) "the Act" means the Preferential Procurement Policy Framework Act, 2000 (Act No. 5 of 2000),

3. FORMULAE FOR PROCUREMENT OF GOODS AND SERVICES

3,1. POINTS AWARDED FOR PRICE

3.1.1. THE 80/20 OR 90/10 PREFERENCE POINT SYSTEMS

A maximum of 80 or 90 points is allocated for price on the following basis;

 $P_{S} = 80 \left(1 - \frac{Pt - Pmin}{Pmin} \right)$ OR $P_{S} = 90 \left(1 - \frac{Pt - Pmin}{Pmin} \right)$

Where

Ps = Points scored for price of tender under consideration

Pt = Price of tender under consideration
Pmin = Price of lowest acceptable tender

3.2. FORMULAE FOR DISPOSAL OR LEASING OF STATE ASSETS AND INCOME GENERATING PROCUREMENT

3.2.1. POINTS AWARDED FOR PRICE

A maximum of 80 or 90 points is allocated for price on the following basis:

 $Ps = 80\left(1 + \frac{Pt - Pmax}{Pmax}\right)$ OR $Ps = 90\left(1 + \frac{Pt - Pmax}{Pmax}\right)$

Where

Ps = Points scored for price of tender under consideration

Pt = Price of tender under consideration
Pmax = Price of highest acceptable tender



4. POINTS AWARDED FOR SPECIFIC GOALS

- 4.1. In terms of Regulation 4(2); 5(2); 6(2) and 7(2) of the Preferential Procurement Regulations, preference points must be awarded for specific goals stated in the tender. For the purposes of this tender the tenderer will be allocated points based on the goals stated in table 1 below as may be supported by proof/ documentation stated in the conditions of this tender:
- 4.2. in cases where organs of state intend to use Regulation 3(2) of the Regulations, which states that, if it is unclear whether the 80/20 or 90/10 preference point system applies, an organ of state must, in the tender documents, stipulate in the case of—
 - (a) an Invitation for tender for income-generating contracts, that either the 80/20 or 90/10 preference point system will apply and that the highest acceptable tender will be used to determine the applicable preference point system; or
 - (b) any other invitation for tender, that either the 80/20 or 90/10 preference point system will apply and that the lowest acceptable tender will be used to determine the applicable preference point system,

then the organ of state must indicate the points allocated for specific goals for both the 90/10 and 80/20 preference point system.

Table 1: Specific goals for the tender and points claimed are indicated per the table below.

Note to tenderers: The tenderer must indicate how they claim points for each preference point system.

	Number of points points points points points points points allocated (80/20 system) system)
Rac	e: Full points allocated to companies who are at least 100% Owned by Black Africans
	DECLARATION WITH REGARD TO COMPANY/FIRM
4.3.	Name of company/firm:
4.4.	Company registration number:
4.5.	TYPE OF COMPANY/ FIRM [tick applicable box] Partnership/Joint Venture / Consortium One-person business/sole propriety Close corporation Public Company Personal Liability Company (Pty) Limited Non-Profit Company State Owned Company
4.6.	I, the undersigned, who is duly authorised to do so on behalf of the company/firm, certify that the points claimed, based on the specific goals as advised in the tender, qualifies the company/ firm for the preference(s) shown and I acknowledge that: 1) The information furnished is true and correct; 1i) The preference points claimed are in accordance with the General Conditions as indicated in paragraph 1 of this form; 1ii) In the event of a contract being awarded as a result of points claimed as shown in paragraphs 1.4 and 4.2, the contractor may be required to furnish documentary proof to the satisfaction of the organ of state that the claims are correct; 1iv) If the specific goals have been claimed or obtained on a fraudulent basis or any of the conditions of contract have not been fulfilled, the organ of state may, in addition to any other remedy it may have — (a) disqualify the person from the tendering process; (b) recover costs, losses or damages it has incurred or suffered as a result of that person's conduct; (c) cancel the contract and claim any damages which it has suffered as a result of having to make less favourable arrangements due to such cancellation; (d) recommend that the tenderer or contractor, its shareholders and directors, or only the shareholders and directors who acted on a fraudulent basis, be restricted from obtaining business from any organ of state for a period not exceeding 10 years, after the audi alteram partern (hear the other side) rule has been applied; and (e) forward the matter for criminal prosecution, if deemed necessary.
	SIGNATURE(S) OF TENDERER(S) SURNAME AND NAME: DATE: ADDRESS:



ANNEXURE A: SPECIFICATION FORM

NAME OF PROCURING FACILITY		L.R.H.		
ITEM DESCRIPTION		ANJUAL SENVICE OF AIRCOUNTROWER 17 1.	I SIPITAL.	
ITEM PURPO	OSE	1. 2.		
ITEM DETAI	LED SPECIFICATION	ON (INCLUDE SIZE, COLOUR, MATERIAL, ETC.)	COMPLIES (YES/NO)	
1.	IME			
2.	bunt of U	mILAn worll.		
3.				
4.				
QUALITY ST	ANDARD	MA.		
	ASURE OR PACK ROLL/PACK/BAIL I			
SAMPLE RE (YES/NO) IF YES WHE	QUIRED N AND HOW?	NIA		
ADDENDUM TO SPECIFICATION ATTACHED (YES OR NO)		YES		

Note:

1.

2.


3.

SPECIFICATION APPROVED BY

	0, 20, 10, (1	IOIT ALL TROPED DI	
Name of End-user (in full)	ANESH SWICHAYER	Name of SCM Rep (in full)	(Sharbare, T
Designation / Rank (in full)	Antisan Porens	Designation/ Rank (in full)	Em bracet
Signature		Signature	
Date	28/01/2025	Date	DELahous
Date	1 5 8 1 0 1 / 5052-	nate	2 SICKTIONS

Bidder Initial here: _____

EVALUATION CRITERIA



Quotation No.	LSH1605/24/25
Quotation Description	ANNUAL SERVICE OF AIR-CONDITIONING SLIT UNIT FOR LADYSMITH REGIONSL HOSPITAL

EVALUATION CRITERIA

This institution intends to evaluate valid quotations using **four (4) evaluation stages**. These are peremptory requirements, should the bidder/tenderer fail to comply with any of the stages as stated below, the quotation will be regarded as non-responsive, and will not progress to the final stage of evaluation:

- Stage 1: Administrative Compliance, Compulsory and Mandatory Requirements
- Stage 2: Capacity to Deliver
- Stage 3: Compliance with Specification
- Stage 4: Price and Preference Points System (Specific Goals)

EVALUATION CRITERIA



STAGE 1: ADMINISTRATIVE, COMPULSORY COMPLIANCE AND MANDATORY REQUIREMENTS

NO.	REQUIREMENTS	INCLUDED IN THE PUBLISHED DOCUMENT?	TO BE RETURNED BY BIDDER/ TENDERER?
	Administrative Compliance	J	
1.	PARTICULARS OF QUOTATION	YES	YES
2.	OFFICIAL PRICE PAGE FOR QUOTATIONS OVER R2 000.01	YES	YES
3.	BIDDER'S DISCLOSURE (SBD4)	YES	YES
4.	GENERAL CONDITIONS OF CONTRACT (GCC)	YES	YES
5.	SPECIAL CONDITIONS OF CONTRACT (SCC)	YES	YES
6.	PREFERENCE POINTS CLAIM FORM IN TERMS OF THE PREFERENTIAL PROCUREMENT REGULATIONS 2022 (SBD 6.1)	YES	YES
	Compulsory Compliance	L	
7.	SUPPLIER UPDATED CIPC REGISTRATION DOCUMENTS	NO	YES
8.	A B-BBEE STATUS LEVEL VERIFICATION CERTIFICATE/ SWORN AFFIDAVIT (For EMEs& QSEs)	NO	YES
9,	CENTRAL SUPPLIER DATABASE COMPLIANCE REPORT (CSD)	NO	YES
	Mandatory Requirements	I	
09.	THE BIDDER MUST PROVIDE PROOF THAT THE ITEMS TO BE SUPPLIED ARE SABS OR SANS APPROVED	NO	YES
10.	CIDB - IME	NO	YES

Note: This relates to administrative, compulsory and mandatory returnable documents which must be fully completed, and submitted, should you fail to submit any of the above returnable documents, your offer will be treated as non-responsive and will not proceed to the next stage of evaluation. The department reserve a right to verify validity of the documents submitted, should it be discovered that the information submitted is misrepresented or falsified the quotation will be disqualified or contract maybe be terminated.

Bidder Initial here:

EVALUATION CRITERIA



STAGE 2: CAPACITY TO DELIVER

1.	Copy of site handing over certificate and completion certificate of previous completed project
2.	As part of risk management, if there is valid proof that the bidder was previously issued with an order and thereafter failed to deliver without acceptable reasons, the bidder will be treated as a defaulter and will not progress to the next stage of evaluation.

STAGE 3: COMPLIANCE WITH SPECIFICATION (SUPPLIER MUST INDICATE WHETHER THEY COMPLY OF NOT COMPLY WITH SPECIFICATION, FAILURE TO INDICATE WILL RESULT TO DISQUALIFICATION)

Requirement	Complies with
·	Specification
	Yes /No
The bidder / Tenderer to confirm that the product supplied complies with attached specification	
document, should you fail to indicate compliance your quotation will not progress to the next	
stage of evaluation.	

STAGE 4: PRICE AND PREFERENCE POINTS

The value of this quotation is estimated not to exceed R 50 000 000 (inclusive of all applicable taxes), therefore the 80/20 preference point system shall be applicable. Points for this quotation will be awarded for:

	CATEGORY	14.7 4 4 4 4 4	POINTS
PRICE			80
SPECIFIC GOALS		 	20
Total points for Price and m	ust not exceed		100

The Department has identified the following specific goal:

Specific Goal	Number of Points allocated	Proof To Claim Specific Goal (Returnable Documents)
RDP GOAL : FULL POINTS ALLOCATED TO COMPANIES WHO ARE ATLEAST 100% OWNED BY BLACK AFRICANS	20	 CIPC Certificate ID Copies CSD Detailed or full report
NOTE:		

Should a responsive bidder fail to submit proof to claim points, as stated above this will not result in disqualification; however, the bidder will not be awarded points for specific goals.

NB SUPPLIERS MUST ENSURE THAT EACH PAGE OF EVALUATION CRITERIA IS INNITIALED BY BIDDER AT THE BOTTOM SPACE PROVIDED.

SUPPLIERS MUST ALSO INDICATE COMPLIANCE WITH SPECIFICATION OF STAGE 2 COLOUMN PROVIDED. SUPPLIERS MUST FULLY COMPLETE ANNEXURE A (SPECIFICATION FORM COLOUMN PROVIDED)

Ridder	Initial	horo:	



PROVINCE OF KWAZULU-NATAL DEPARTMENT OF HEALTH-LADYSMITH REGIONAL HOSPITAL ZNQ NO......UTHUK-H- FUNDED FROM CAT "B" APPOINTMENT OF CONTRACTOR TO CARRY OUT THE SERVICING OF AIRCORN SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL

Closing Date & Time	:@ 11h00
Contract Period	: Three Weeks (03).
Validity Period	:Days
Technical Contact Person	: Mr. L.L. Makhaye
Contact Telephone Number	: 036-637 2111
On Site Inspection	: No Site inspection
DOCUMENTS DELIVERED BY HAND MUST IN:	BE DEPOSITED IN THE QUOTATION BOX SITUATED
THE TENDER-BOX LADYSMITH REGIONAL HOSPITAL IN MAIN GATE SECURITY MALCOLM ROAD, LADYSMITH,3370	THE QUOTATION BOX IS AVAILABLE ON MONDAYS TO FRIDAY - EXCESS PERMISSION WILL BE OBTAINED FROM THE MAIN GATE SECURITY.
N.B.: TENDER BOX WILL BE CLEARED AT 110 Name of Tenderer	0Hrs ON THE CLOSING DATE.
BID FOR APPROVAL BY THE DEPARTMENTA	AL BID SPECIFICATION COMMITTEE
	REFERENCE: -H- ENQUIRIES: MR. L.L. (HAYE
140 ti	DATE:
Name of Tenderer	
PROVINCIAL SUPPLIERS DATABASE REGISTRATIONO.:	ON
SUPPLIERS DATABASE REGISTRATION CLASSIFICATION	N :(Tick (✓) applicable block)
SUPPLIER PROVISIONAL S	



PROVINCE OF KWAZULU-NATAL DEPARTMENT OF HEALTH-LADYSMITH REGIONAL HOSPITAL ZNQ NO......UTHUK-H- FUNDED FROM CAT "B" APPOINTMENT OF CONTRACTOR TO CARRY OUT THE SERVICING OF AIRCORN SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL

ZNQ:		
/ 3UE.1"		

<u>DOH – LRHMNTNSI –CAT'B'-2024/25 – PREVENTATIVE MAINTENANCE</u> <u>MID</u> MAJOR SERVICES-OFFICE WALL AIR-CONDITIONING UNITS (SPIT-UNIT)

- 1. PROJECT SPECIFICATIONS
- 1.1 SCOPE OF CONTRACT

This Contract is for the execution of the project indicated above.

- 1.2 CONTRACT DRAWINGS
 - 1.2.1 Service will be based on the specification
- 1.3 CONDITIONS OF CONTRACT AND PRELIMINARIES
- 1.3.1 PERIOD OF CONTRACT

Three (03) Weeks as the Contract Period for the completion of the Work from date of Site handover.

NB. Contractor will be given seven (7) working days to resume duties after the order with order number has been issued. Failure to do so, an evaluation committee will re-evaluate and re-issue the order to the next following contractor on condition that contractor meets all the requirements.

1.3.2 CONTRACT GUARANTEE:

Damage to the existing buildings - Bidders to note that any damages done or occurring to any of the buildings will be repaired at the expense of the contractor/Tenderer.

The repairs/construction must be to the satisfaction of the Kwa Zulu- Natal Department of

Health (Ladysmith Regional Hospital).

Bidders are advised to visit the site prior to tendering and to acquaint themselves with the nature of the works to be done and access to the sitting of the existing buildings/site etc., as no claim whatsoever will be allowed on the grounds of bidders ignorance of the conditions under which the work will be executed.

1.3.3 GUARANTEE PERIOD

The guarantee period for the completion of the Structure indicated above and all materials must be a minimum of <u>twelve (12) Calendar Months</u> from the date of final delivery.



Materials / parts replaced shall carry a guarantee for at list three months or as per manufactures specification.

1.3.3.1 PENALTY ON NON PROJECT / SERVICE COMPLETION AS PER CONTRACT

Penalties of 0.04% a day shall apply for non-completion of the projects. Percentage is based on the total tender amount excluding V.A.T Penalties will be applied where there are no reasons stated by contractor.

1.3.4 SITE AND MODE OF PROCEDURE

The work contained in this contract will be carried out on the existing site of the existing

Ladysmith Regional Hospital

The Bidder is advised that the existing premises will be fully occupied throughout the period of the contract, and that the minimum amount of disruptions to services is of the utmost importance.

Damage to the existing buildings - Bidders to note that any damages done or occurring to any of the buildings will be repaired at the expense of the contractor/ Bidder. (Refer to 1.3.2 contract guarantee)

The **service** must be to the satisfaction of the Kwa Zulu-Natal Department of Health. Bidders are advised to visit the site prior to tendering and to acquaint themselves with the nature of the works to be done and access to the sitting of the existing buildings/site etc., as <u>no claim whatsoever</u> will be allowed on the grounds of bidders ignorance of the conditions under which the work will be executed. (Refer to 1.3.2 contract guarantee)

1.3.5 SATISFACTORY INSTALLATION

Installation/construction/repairs/service shall be carried out in accordance with the South African Bureau of Standards (SABS) Code of Practice for the application of National Building Regulations, the KZNPA Standard Preambles to all Trades, the KZNPA General Specification, the South African Bureau of Standards Code of Practice and the Occupational Health and Safety Act and Regulations 85/1993 as amended.

Copies of the KZNPA Standard Preambles to all Trades and the KZNPA General Specification are available at the tender board for Health – KwaZulu-Natal (Infrastructure head office) and can be obtained on request.

1.3.6 CERTIFICATE OF COMPLIANCE

Mechanical replaced parts guarantee certificate

1.3.7 GENERAL

The Bidders / Contractors will be responsible for all masonry work associated with the installation/construction/repairs and making good of all work related to the installation. The patching/tarmac/concrete and painting (If Any) must be to the satisfaction of the KwaZulu-Natal Department of Health Ladysmith Regional Hospital).

2. TECHNICAL SPECIFICATION

2.1 GENERAL



This TECHNICAL SPECIFICATION shall be read in conjunction with all other sections of the SPECIFICATION and in cognisance shall be taken of the clauses relevant to this particular installation/construction/repairs, whether any specific clauses are referred to or not.

2.1.1 SCOPE

Supply all materials /parts required/transportation to the completion of works as indicated in the BOQ including labour and as SPECIFIED for the servicing of theatre lights and materials that are used are to comply with ISO 9001:2008 Standards. The bidder is to ensure that new materials /parts installed are as per manufactures specifications and all required miscellaneous are inclusive in the quote / materials / parts shall be allowed by contractor for the completion of the projects / works / service.

2.1.2 WORK TO BE CARRIED OUT

Supply and install the following:

- 1. Start up the air-conditioning unit using the remote.
- 2. Replace AAA batteries in all remotes (use Duracell batteries only).
- 3. Remove indoor filter unit, clean and replace.
- 4. Check compressor, and report any irregular noise.
- 5. Check condenser fan, and report any irregular noise.
- 6. Check indoor blower / unit fans and report any irregular noise.
- 7. Check the entire unit when it's running for any irregular noise.
- 8. Check all wiring for loose connections or burnt wiring and repair.
- 9. Check starting capacitors and relays, replace if it's necessary.
- 10. Strip external condensing unit, clean using yellow chemical.
- 11.Re-assemble external condensing unit.
- 12. Clean the indoor unit using anti-bacterial chemical.
- 13. Make use of portable LP or HP service gauges, check for gas leaks
- 14. Make use of electronic leak detection unit, check for gas leaks, mostly on discharge and suction line flare nuts, check for wet areas.
- 15. Make use of R22 or C°2 to flush drainage system.
- 16. Replace drainage pipe if needs be client request.
- 17.Test run air-conditioning unit and ensure no water leaks from the In door units.
- 18. Tighten all loose bolts in there any.
- 19. Clean the plant room or area around condensing unit.
- 20. Fill all check lists and submit to Chief Artisan.
- 21. Report all missing remotes.
- 22. Check functionality of the isolator Isolators
- 23. Report all office who run their air-conditioning units with windows / doors open

24. Compile and submit after service report with recommendations

25. Compile and submit condemning certificate for equipment which is beyond economical repairs.



PROVINCE OF KWAZULU-NATAL DEPARTMENT OF HEALTH-LADYSMITH REGIONAL HOSPITAL ZNQ NO......UTHUK-H- FUNDED FROM CAT "B" APPOINTMENT OF CONTRACTOR TO CARRY OUT THE SERVICING OF AIRCORN SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL

ZNQ	

<u>DOH – LRHMNTNSI –CAT'B'-2024/25 – PREVENTATIVE MAINTENANCE</u> <u>MID</u> <u>MAJOR SERVICES-OFFICE WALL AIR-CONDITIONING UNITS (SPIT-UNIT)</u>

3. SCHEDULE OF RATES

PREAMBLE TO SCHEDULE OF RATES

Items and Pricing

The Department reserves the right to place an order for any quantities of items included in the Schedules. The Schedule of Rates must also not be assumed to include and describe every detail of the supply requirement, but must be taken and read in conjunction with the other parts of the document. Thus the supplier shall not have claim for further payment in respect of any order, which may be described or implied in the contract, although apparently no corresponding items are given in the Schedule of Rates. The supplier shall be deemed to have satisfied himself before tendering as to the correctness and sufficiency of his tender for the contract and of the rates and prices stated in the Schedule of Rates.

Tax and Duties

Prices, tendered and paid, must include all customs, excise and import duties, and any other tariffs or taxes levied by the government or statutory body having jurisdiction on the goods provided under this contract, **including 15% Value Added Tax (applicable to the current rate)**.

Rates

Except where provision is made in the Schedule of Rates, the rates and prices inserted shall be the full rates and prices for the service delivered described under the respective items and shall cover all labour, transport, overhead charges and profit, etc. as well as the general liabilities, obligations and risks arising out of the Conditions of Contract, the overhead charges and profit being spread proportionately over the rates of the relative items in the Schedule of Rates.



DEPARTMENT OF HEALTH-LADYSMITH REGIONAL HOSPITAL ZNQ NO...........UTHUK-H- FUNDED FROM CAT "B" APPOINTMENT OF CONTRACTOR TO CARRY OUT THE SERVICING OF AIRCORN SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL

	스NQ.
--	------

<u>DOH – LRHMNTNSI –CAT'B'-2024/25 – PREVENTATIVE MAINTENANCE</u> <u>MID</u> <u>MAJOR SERVICES-OFFICE WALL AIR-CONDITIONING UNITS (SPIT-UNIT</u>

Item	DESCRIPTION	UNIT	QTY	RATE/ UNIT	,	TOTAL	
				R	c	R	С
,	NOTES: 1) All rates for items contained in this Schedule of Prices must be computed excluding the applicable Sales Tax. 2) Where items are described as "Or other approved", approval must be obtained prior to tendering or submission of documents. 3) All rates quoted shall be inclusive of transport, labour and profit. 4) caution to be taken to do the exact measurements before submission is done 5) Ladysmith Hospital will not be responsible for any mistakes and underquoting All Technical enquiries should be communicated with maintenance department at the Hospital prior						
	to filling and submitting of the document INSTITUTION: LADYSMITH REGIOANAL HOSPITAL SERVICE: OFFICE MIDWALL SPLIT AIRCONDITIONING UNIT ZNQ:						
	PROPRIETARY ARTICLES: All equipment and material QUOTED in this contract shall be that which is specified or other approved by the Department of Health Facilities Management. See specification bellow.						
1.	Maintenance Offices (Foreman) Major maintenance to 18000 BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit	each	01 .				
2.	Chief Artisan Office Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor Split air-conditioning unit	each	01				
3	Maintenance Tea Room Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor Split air-conditioning unit	each	01				



	REPUBLIC OF SOUTH AFRICA				
	Asset Managers Office				
2	Major maintenance to 24000BTU Carrier midwall split				
3.	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor Split air-conditioning unit.	each	01		
	Waste Manager & Healthy and Safety Officer.				
	Major maintenance to 12000BTU Carrier midwall split				
5.	air-conditioning inverter unit Refer Page 04 Work To Be				ĺ
	Carried Out by the contractor Split air-conditioning unit	each	01		
	A.D. Systems	- Cucii	01		
		1			
	Major maintenance to 12000BTU Carrier midwall split				
	air-conditioning inverter unit Refer Page 04 Work To Be	1	01		
	Carried Out by the contractor Split air-conditioning unit	each	01		
	Supply Chain Management (Warehouse)				
6.	Major maintenance to 18000BTU Carrier midwall split				
"	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor Split air-conditioning unit	each	02	 1	
	Supply Chain managers Office				
7.	Major maintenance to 12000BTU Carrier midwall split				
/•	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor Split air-conditioning unit.	each	01		
	Demand Office				
	Major maintenance to 12000BTU Carrier midwall split				
8	air-conditioning inverter unit Refer Page 04 Work To Be		ļ		
Ī -	Carried Out by the contractor in in each Split air-				
	conditioning unit	Each	01		
	Acquisition				
	Major maintenance to 12000BTU Carrier midwall split		1		
9	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor in each equipmen	Each	01		'
	Logistics				
	Major maintenance to 18000BTU Carrier midwall split		ļ		
10	air-conditioning inverter unit Refer Page 04 Work To Be				
10	Carried Out by the contractor in each Split air-				
	conditioning unit	Each	01		
	High Risk Area			1 1	
	Major maintenance to 12000BTU Carrier midwall split				
11	air-conditioning inverter unit Refer Page 04 Work To Be				
11	Carried Out by the contractor in each Split air-				
		Each	01		
	conditioning unit	Dacii	1 01	 -	 -
1	Home Affairs Office				
	Major maintenance to 12000BTU Carrier midwall split				
12	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor in each Split air-	Tr = +1-	01		1
	conditioning unit	Each	01	 -	 -
	KMC Office Consulting room No1				
	Major maintenance to 12000BTU Carrier midwall split				
13	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor in each Split air-		0.		
	conditioning unit	Each	01	 	 -
	KMC Office Consulting room No2				
-	Major maintenance to 12000BTU Carrier midwall split			[
14	air-conditioning inverter unit Refer Page 04 Work To Be				
	Carried Out by the contractor in each Split air-				
	conditioning unit	Each	01	 _	
15	Psychiatric Clinic Consulting room No1.No2. & No.3	Each	03		
L		-		 	



	REPUBLIC OF SOUTH AFRICA						
	Major maintenance to 12000BTU Carrier midwall split						T
	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-						
	conditioning unit						
	CDC Clinic Consulting room No1,2,3&4						
	Major maintenance to 12000BTU Carrier midwall split						
16	air-conditioning inverter unit Refer Page 04 Work To Be						
10	Carried Out by the contractor in each Split air-		}				
		Trook	04				
<u> </u>	conditioning unit	Each	04		_		
	CDC Clinic waiting area						
	Major maintenance to 32000BTU Carrier midwall split						
17	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor each Split air-conditioning						
	unit.	Each	01				
	CDC Filling Room						
18	Major maintenance to 36000BTU Carrier midwall split						
10	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor each Split air-conditioning	Each	01				
	CDC Park Home	1 -				***************************************	
	Major maintenance to 12000BTU Carrier midwall split						
19	air-conditioning inverter unit Refer Page 04 Work To Be						
17	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	08				
	CHC HCT Park Home	Lacii	00				
	i						
20	Major maintenance to 12000BTU Carrier midwall split						
20	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-	_ ,					
	conditioning unit	Each	02				
	Ward 11/Eye Clinic						
1	Major maintenance to 18000BTU Carrier midwall split						
21	air-conditioning inverter unit Refer Page 04 Work To Be						İ
	Carried Out by the contractor in each Split air-		i				
	conditioning unit	Each	01				
	Ward 6						
	Major maintenance to 12000BTU Carrier midwall split		1				
22	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	01				
	Ward 9			****			†
	Major maintenance to 12000BTU Carrier midwall split				***************************************		-
23	air-conditioning inverter unit Refer Page 04 Work To Be]				
-5	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	01				
	NICU	1./40/11	1 01				-
	Major maintenance to 12000&24000BTU Carrier						[
24							
24	midwall split air-conditioning inverter unit Refer Page						
	04 Work To Be Carried Out by the contractor in each	Pack	02				
	Split air-conditioning unit.	Each	02				ļ
	Mortuary Office						
	Major maintenance to 12000BTU Carrier midwall split						
25	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	01				<u> </u>
26	Office of Transport Management Officer						
	Major maintenance to 12000BTU Carrier midwall split	Each	01				



dis-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit 7		REPUBLIC OF SOUTH AFRICA					
Carried Out by the contractor in each Split air- conditioning unit Office of Transport Officers Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit ender Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit ender Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit ender the contractor in each Split air- conditioning unit ender Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit ender Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit ender Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security Carner Room Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security Carner Room Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security Carner Room Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Criese Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Sp		air-conditioning inverter unit Refer Page 04 Work To Be					
conditioning unit Office of Transport Officers Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit maintenance to 12000BTU Carrier midwall split air-conditioning unit Plan macy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit with the contractor in each Split air-conditioning unit maintenance to 12000BTU Carrier midwall split air-conditioning unit each Split air-conditioning unit merter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit each each split air-conditioning unit each each each each each each each each				İ		i	
Office of Transport Officers Major maintenance to 12000BTU Carrier midwall split air-conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning univerter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning univerter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Carrier midwall split air-conditioning unit KZN Security Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Car					İ		
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit PRO Gried Out by the contractor in each Split air-conditioning unit Paramacy Store Room Next to Transport Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security FSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Carrier unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit air-conditioni							
27 alr-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Real Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit air-conditioning unit unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit air-conditioning unit unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer		Office of Transport Officers			ĺ		İ
Carried Out by the contractor in each Split airconditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split airconditioning unit each Split airconditioning unit each Split airconditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split airconditioning unit each Split airconditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit KZN Security PSO KZN Security Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Carrier midwall split air-conditioning unit KZN Security Carrier Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit KZN Security Carrier Noom Major maintenance to 18000BTU Carrier midwall split air-conditioning unit KZN Security Carrier Noom Major maintenance to 12000BTU Carrier midwall split air-conditioning unit air-conditioning u							
conditioning unit PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each 01 Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each 01 KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit enance to 12000BTU Carrier midwall split air-conditioning unit enance to 1800BTU (2x24000), (2x12000) Crises Centre Major maintenance to 36000BTU (2x24000), (2x12000) Carrier dout by the contractor in each Split air-conditioning unit enance Split air-conditioning unit enance Split air-conditioning unit enance Split air-conditioning unit enance Split air-conditioning unit enance Split air-conditioning unit enance Split air-conditioning unit enance S	27						
PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning unverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 KZN Security FSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 TB Clinic Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 TB Clinic Criese Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning miverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning miverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning miverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning miverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning miverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning miverter unit Refer Page 04 Work To Be Carrier Midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carrier Out by the		Carried Out by the contractor in each Split air-					
PRO Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit 2. Switchboard			Each	01			
Major maintenance to 1200BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security FSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security FSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Criese Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Criese Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the cont							
28 air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Navay Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Navay Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit							
Carried Out by the contractor in each Split air- conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning univerter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security CSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each I SZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit revers unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit N-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carlier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit	20						
conditioning unit Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TR Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O5 Switchboard	20						
Pharmacy Store Room Next to Transport Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each 01 Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TR Clinic Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TR Clinic Air Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TAR Clinic Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit X-Ray Major maintenance to 12000BTU (2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit each Split air-conditioning unit each Split air-conditioning unit each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Wor			Each	01	ļ		
Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning mid inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O1 TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Refer Page 04 Work To Be Carried Out by th			Each	V1	 		
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU.(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU.(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 33 34 35 36 37 38 38 39 39 30 30 30 30 30 31 31 32 32 33 34 35 35 36 37 37 38 38 39 30 30 30 30 30 3				1			
Carried Out by the contractor in each Split air- conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit X-Ray Major maintenance to 36000BTU.(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in							
conditioning unit Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 01 Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each 01 KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work T	29	air-conditioning inverter unit Refer Page 04 Work To Be					
Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning mit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard		Carried Out by the contractor in each Split air-					
Renal Unit Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each O1 Each O1 Each O1 Each O1 KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each O1 KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard		conditioning unit	Each	02			
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Transplant of the page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Contre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each O2 Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU (2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O3 Switchboard							
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard					İ		
Carried Out by the contractor in each Split air- conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- each Split air-conditioning unit Switchboard	30						
conditioning unit Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by	30				·		
Laundry Managers Office Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning unit KZN Security PSO Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard			Rach	01	İ	İ	}
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 01 KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 01 KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 01 TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU (2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 X-Ray Major maintenance to 36000BTU, (2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 05			Eacii	01			-
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU_(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O3 X-Ray Major maintenance to 12000BTU carrier midwall split air-conditioning unit Each O3 Switchboard	Į		İ		***************************************	***************************************	
Carried Out by the contractor in each Split airconditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit Each Crises Centre Major maintenance to 12000BTU Carrier midwall split airconditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split airconditioning unit Each O2 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O3 Switchboard					l	İ	
conditioning unit KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 01 KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TE Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 Switchboard	31	air-conditioning inverter unit Refer Page 04 Work To Be					
KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard Each 01 Each 02 Each 03 Each 05		Carried Out by the contractor in each Split air-					
KZN Security PSO Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard	İ	conditioning unit	Each	01			
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 33 Each 34 35 Each 36 Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 36 Each 37 Each 38 Each 91 Each 92 Each 93 Each 94 Each 95 Each 95 Each 95 Each 96 Each 97 Each							
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard							
Carried Out by the contractor in each Split air- conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each O2 Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each O3 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O5 Switchboard	32			j			
conditioning unit KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 Switchboard	34						
KZN Security Camera Room Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Switchboard			Fach	01			
Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 35 air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 36 Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard			Duch		 		
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 36 Switchboard							
Carried Out by the contractor in each Split air- conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 02 Lach O2 Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning unit Each O3 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O5 Switchboard				-			
conditioning unit TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) 36 Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 55 Each 60 E	33						
TB Clinic Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) 36 Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard		_					
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard		conditioning unit	Each	01	 		ļ
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 55 Switchboard		TB Clinic					
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 55 Switchboard	ĺ	Major maintenance to 12000BTU Carrier midwall split					
Carried Out by the contractor in each Split air- conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each O2 Lack A-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each O3 Switchboard	34						1
conditioning unit Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 03 Each 05 Switchboard	"	Carried Out by the contractor in each Split air-					
Crises Centre Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 55 Switchboard			Each	02			
Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 35 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard			Lucii		 		†
air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard							
Carried Out by the contractor in each Split air- conditioning unit Each 03 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 05 Switchboard							
conditioning unit Each 03 X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each 05 Switchboard	35						
X-Ray Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Each Switchboard						-	
Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard Each 05			Each	03			1
Major maintenance to 36000BTU,(2x24000), (2x12000) Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard Each 05		X-Ray					
Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard Each 05		Major maintenance to 36000BTU,(2x24000), (2x12000)					
Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit Switchboard Each 05	36	Carrier midwall split air-conditioning inverter unit Refer					
each Split air-conditioning unit Each 05 Switchboard	~	Page 04 Work To Be Carried Out by the contractor in		1			
37 Switchboard			Each	05			
	<u></u>			†	 		
Major manifestance to 12000010 Carrier informati spite Each O1	37		Fach	01			
	L	inagor manuenance to 12000510 Carrier iniciwan spin	Lacii	1 01		_L	



	REPUBLIC OF SOUTH AFRICA					
	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
İ	conditioning unit					
	Senior Medical Manager's Office		 	 		
	Major maintenance to 12000BTU Carrier midwall split					
38	air-conditioning inverter unit Refer Page 04 Work To Be		[[
	Carried Out by the contractor in each Split air-	177 L	01		}	
	conditioning unit	Each	01	 _		
	CEO Office					
	Major maintenance to 18000BTU Carrier midwall split			ĺ		
39	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	01			ļ
	Deputy Director's Office					
	Major maintenance to 12000BTU Carrier midwall split					
40	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					1
	conditioning unit	Each	01			
	Deputy Director: Finance					
	Major maintenance to 12000BTU Carrier midwall split					
41	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	01			
	Registry Office					
Ì	Major maintenance to 12000BTU Carrier midwall split			į		
42	air-conditioning inverter unit Refer Page 04 Work To Be			ļ		
'-	Carried Out by the contractor in each Split air-			-		
	conditioning unit	Each	01			
	CEO's Secretary Office		1			
	Major maintenance to 12000BTU Carrier midwall split					
43	air-conditioning inverter unit Refer Page 04 Work To Be			***************************************		
7-2	Carried Out by the contractor in each Split air-				1	
	conditioning unit	Each	01			
-	Senior Medical Manager Secretary Office	Laci		_		
	Major maintenance to 12000BTU Carrier midwall split	-		A	Ì	
	air-conditioning inverter unit Refer Page 04 Work To Be			Ì		
	Carried Out by the contractor in each Split air-			1		
		Each	01			
	conditioning unit	Lacii	V1	 		ļ
	HR. Offices Major maintenance to 12000 BTH Carrier midwell split]				
11	Major maintenance to 12000BTU Carrier midwall split		1			
44	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-	D1	,,			
<u> </u>	conditioning unit	Each	17	 +		
	Social Worker Office Next to transport					
1 , -	Major maintenance to 12000BTU Carrier midwall split			İ		
45	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-	m	,			
	conditioning unit	Each	01	 		
	Wellness Centre					-
	Major maintenance to 12000BTU Carrier midwall split	[
46	air-conditioning inverter unit Refer Page 04 Work To Be				!	
	Carried Out by the contractor in each Split air-	<u> </u> .				
<u> </u>	conditioning unit	Each	05	 		
47	Informatics					
	Major maintenance to 12000BTU Carrier midwall split	Each	01		l	



	HEALTH REPUBLIC OF SOUTH AFRICA					
	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit					
		 				$\vdash \neg \vdash$
	Telkom Operator's Office					
	Major maintenance to 12000BTU Carrier midwall split		ļ			
48	air-conditioning inverter unit Refer Page 04 Work To Be		минени			
	Carried Out by the contractor in each Split air-		. 1			
	conditioning unit	Each	01			ļ <u>.</u>
	Lecture Room					
	Major maintenance to 18000BTU Carrier midwall split					
49	air-conditioning inverter unit Refer Page 04 Work To Be		1			
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	02			
	Staff Residence (Nurses Home) Park homes	24441				
	Major maintenance to 12000BTU Carrier midwall split			İ		
50			ĺ			
50	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-		06			
	conditioning unit	Each	06	 		1
	ICU					1
	Major maintenance to 18000BTU Carrier midwall split					
51	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	04			
·	Day Ward					
	Major maintenance to 12000BTU Carrier midwall split					
52	air-conditioning inverter unit Refer Page 04 Work To Be					
32	Carried Out by the contractor in each Split air-					
ļ		Each	03			
	conditioning unit	Eacii	03			+
	Quality Manager					
	Major maintenance to 12000BTU Carrier midwall split					
53	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	01			<u> </u>
	Infection control Office					
	Major maintenance to 12000BTU Carrier midwall split			1		
54	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-				İ	
	conditioning unit	Each	01			
	F1					1
	Major maintenance to 12000BTU Carrier midwall split		-			
55	air-conditioning inverter unit Refer Page 04 Work To Be		***************************************			
33	Caminal Out has the contractor in each Culit air		1			
	Carried Out by the contractor in each Split air-	177 I	01			
	conditioning unit	Each	01	 		+
	M1					
	Major maintenance to 12000BTU Carrier midwall split					
56	air-conditioning inverter unit Refer Page 04 Work To Be					
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	01	 		
	Dental					
	Major maintenance to 12000BTU Carrier midwall split					
57	air-conditioning inverter unit Refer Page 04 Work To Be					1
	Carried Out by the contractor in each Split air-					
	conditioning unit	Each	02			
		1		 		+
3	1772	1	1	1		
58	E3 Major maintenance to 12000BTU Carrier midwall split	Each	02			



	REPUBLIC OF SOUTH AFRICA						
	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-		l i				
	conditioning unit						
	Matrons Office						
	Major maintenance to 12000BTU Carrier midwall split						
56	air-conditioning inverter unit Refer Page 04 Work To Be						
30	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	04				
	Wound Care	Lacii	04				
	Major maintenance to 12000BTU Carrier midwall split]
57	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-	- ,					
<u></u>	conditioning unit	Each	01				
1	Rehab		l				
	Major maintenance to 18000BTU Carrier midwall split						
58	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	10				
	Finance						
	Major maintenance to 1X18000 and 1x 1200 BTU						
59	Carrier midwall split air-conditioning inverter unit Refer						
	Page 04 Work To Be Carried Out by the contractor in						
	each Split air-conditioning unit	Each	02				
	Cafeteria No.2						
	Major maintenance to 18000BTU Carrier midwall split						
60	air-conditioning inverter unit Refer Page 04 Work To Be	-					
00	Carried Out by the contractor in each Split air-		1				
		Each	02		ļ		'
	conditioning unit	Each	02				
	Small Boardroom						
	Major maintenance to 12000BTU Carrier midwall split						İ
61	air-conditioning inverter unit Refer Page 04 Work To Be						
	Carried Out by the contractor in each Split air-	n 1					
	conditioning unit	Each	01				├
	Medical Records						
	Major maintenance to 24000BTU Carrier midwall split						
62	air-conditioning inverter unit Refer Page 04 Work To Be				İ		
	Carried Out by the contractor in each Split air-						İ
l	conditioning unit	Each	01				<u> </u>
	Ward 13						-
	Major maintenance to 12000BTU Carrier midwall split						*
63	air-conditioning inverter unit Refer Page 04 Work To Be	1					-
	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	01				
	Dietician						
	Major maintenance to 12000BTU Carrier midwall split						
64	air-conditioning inverter unit Refer Page 04 Work To Be						
"	Carried Out by the contractor in each Split air-						
	conditioning unit	Each	01				
	Main kitchen						
	Major maintenance to 12000BTU Carrier midwall split						
65	air-conditioning inverter unit Refer Page 04 Work To Be						'
65	Carried Out by the contractor in each Split air-						
		Each	03				
	conditioning unit	Each	0.5	•			
66	PHC Major maintenance to 18000BTU Carrier midwall split	Each	20				
L	Integer maintenance to 10000010 Carrier intowart spirit	Lacil	20			1	1



Carr	ried To Collection Summary PS 1		16	R		
			178			<u> </u>
77	Revenue Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit	Each	05			
71	Server Room (ENT Block) Major maintenance to 18000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit	Each	02			
70	M&E Office Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air-conditioning unit	Each	01			
69	Social Worker next to ICU Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit	Each	01		Altonormalianismanismanismanismanismanismanismanis	
68	C Top Major maintenance to 12000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit	Each	03			
67	PHC under ceiling Major maintenance to 24000BTU Carrier midwall split air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit	РНС	04			- Company of the Comp
	air-conditioning inverter unit Refer Page 04 Work To Be Carried Out by the contractor in each Split air- conditioning unit			1		

Item	DESCRIPTION	UNIT	QTY	RATE/ UN	IT	ТОТА	L
				R	С	R	С



on this document.

Tenderer_____

I/We undertaken to complete the project within three (03) weeks

Signature_____Position___

PROVINCE OF KWAZULU-NATAL
DEPARTMENT OF HEALTH-LADYSMITH REGIONAL HOSPITAL
ZNQ NO......UTHUK-H- FUNDED FROM CAT "B"
APPOINTMENT OF CONTRACTOR TO CARRY OUT THE SERVICING OF AIRCORN SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL

COUNTY TO SEAS TOWN THE COUNTY TEST THE
ZNQ:
DOH - GTNMNTNSI -CATB-2020/21 - PREVENTATIVE MAINTENANCE
MAJOR SERVICES-OFFICE MIDWALL AIR-CONDITIONING UNI
MINIMUM REQUIREMENTS FOR MAJOR SERVICING OF AIR-CORNS SPLIT UNIT FOR LADYSMITH REGIONAL HOSPITAL
 1) 1ME 2) 3 X Handing over Certificates for servicing of Air-Conditioning split unit With 3 X completion Certificates for servicing of Air-Conditioning split unit 3) At least two (02) qualified artisans in air-Corn and Refrigeration-servicing and repairs (Certificate to be attached).
NB. Contractor must ensure that a proper PPE is worn throughout the duration of the contract with name tags on at all times.
Contractor must ensure that they come up their tools, <u>NO</u> tool will be issued by the Hospital to the contractor.
Declaration
I have read with understanding and agree to all terms and conditions and requirements printed